

# STATEMENT OF COMPLIANCE TO THE TECHNICAL SPECIFICATIONS

## SUPPLY, DELIVERY AND INSTALLATION OF RACKMOUNT UNINTERRUPTIBLE POWER SUPPLY (UPS) BATTERIES

Bidders must state here either **“Comply”** or **“Not Comply”** against each of the individual parameters of each Specification stating the corresponding performance parameter of the equipment offered. **Statements of “Comply” or “Not Comply” must be supported by evidence in a Bidder Bid and cross-referenced to that evidence. A statement that is not supported by evidence or is subsequently found to be contradicted by the evidence presented will render the Bid under evaluation liable for rejection. A statement either in the Bidder's statement of compliance or the supporting evidence that is found to be false either during Bid evaluation may be regarded as fraudulent and render the Bidder or supplier liable for prosecution subject to the applicable laws and issuances.**

| ITEM NO.  | SPECIFICATIONS  | STATEMENT OF COMPLIANCE |               |  |            |   |               |  |
|---|---|-------------------------|---------------|--|------------|---|---------------|--|
| 1   | <p><b>SCOPE OF WORK/SERVICES</b></p> <p>Equipment Background:</p> <p><b>The following UPS equipment shall cover the supply, delivery and installation of UPS batteries.</b></p> <table border="1" style="width: 100%; border-collapse: collapse;"> <thead> <tr> <th style="text-align: left;">Existing Rackmount UPS</th> <th style="text-align: left;">Serial Number</th> </tr> </thead> <tbody> <tr> <td>1. Eaton 6KVA Rackmount UPS 9PX6KiRT 9PX</td> <td>P203J11C45</td> </tr> <tr> <td>2. Delta RT-6K 6KVA Rackmount UPS with Battery Pack</td> <td>ACO22600404WE</td> </tr> </tbody> </table> | Existing Rackmount UPS  | Serial Number | 1. Eaton 6KVA Rackmount UPS 9PX6KiRT 9PX | P203J11C45 | 2. Delta RT-6K 6KVA Rackmount UPS with Battery Pack | ACO22600404WE |  |
| Existing Rackmount UPS                              | Serial Number   |                         |               |  |            |   |               |  |
| 1. Eaton 6KVA Rackmount UPS 9PX6KiRT 9PX            | P203J11C45  |                         |               |  |            |   |               |  |
| 2. Delta RT-6K 6KVA Rackmount UPS with Battery Pack | ACO22600404WE   |                         |               |  |            |   |               |  |
| 2   | <b>Check UPS Measurement, statuses, and alarms.</b>   |                         |               |  |            |   |               |  |
| 3   | <b>Disconnection and dismantling of battery modules / battery pack.</b>   |                         |               |  |            |   |               |  |
| 4   | <b>Inspection of new battery module units, check the voltage supply before inserting the new battery module /battery pack.</b>  |                         |               |  |            |   |               |  |
| 5   | <b>One (1) year warranty on parts and services.</b>   |                         |               |  |            |   |               |  |

\_\_\_\_\_  
Name of Company/Bidder

\_\_\_\_\_  
Signature over Printed Name  
of Representative

\_\_\_\_\_  
Date